

FAIRFAX COUNTY FIRE AND RESCUE PREVENTION
DIVISION POLICIES, OPERAITONS AND PROCEDURES
ISSUED BY:
REISSUE DATE: JANUARY 1, 1999
DEPUTY FIRE CHIEF CLARK O. MARTIN, JR
SUBJECT:
DESIGNED REQUIRMENTS FOR PROJECT SITE PLAN
INDICATION OF FIRE LANE MARKINGS AND SIGNS

TO: All Contractors, Engineers, Architects, Designers, and Installers

The <u>Fairfax County Public Facilities Manual</u> requires the installation of fire lanes as part of the public utilities requirements. The <u>Fairfax County Fire Prevention Code</u> governs the dedication of the fire lane as well as the installation and sign specifications.

Posting and marking of fire lanes was required as of July 1986, for all sites regardless of Use Group classification. Under certain situations, additional areas may be designated as fire lanes as conditions warrant.

All fire lane information must be applied in a clear and orderly manner to the original mylar. All fire lanes must be shown on a site plan that is part of the site plan submittal set and all sets must have the fire lane plan included. The site plan scale can be no smaller than 1:500 (metric). Street names and building addresses are to be shown. Plans submitted must indicate fire lanes designated in accordance with Fire Prevention criteria. A summary of the information necessary to create fire lanes acceptable to Fairfax County Fire and Rescue is on the following pages.

FIRE LANE DESIGNATIONS

Under Section F311.0 of the Fairfax County Fire Prevention Code, the Office of the Fire Marshal is authorized to designate fire lanes on public streets and on private property where necessary. This is to prevent parking in front of, or adjacent to, fire hydrants and to provide access for fire fighting equipment. Markings and signs are to be provided by the owner or agent of the property involved. Parking or otherwise obstructing such areas is prohibited.

I. HYDRANTS

- A. Parking is prohibited within 4.6 m. of a fire hydrant located along the curb line or edge of any public or private roadway. No special curb marking is required for enforcement.
- B. Fire hydrants installed in parking lots are located within a fire lane. Curb and/or roadway marking is required in accordance with sections III and IV below.

II. FIRE LANES

A. Fire lanes shall be installed where required by the Office of the Fire Marshal. Fire lanes shall be marked with both sign and curb delineation per section III and IV below. Parking and traffic flow patterns shall be required as follows:

STANDARD REQUIREMENTS

~ 1		
Street Width	One-Way	Two-Way
Curb to Curb	Traffic	Traffic
less than 7.2 m.	no parallel parking	no parallel parking on
	on either side of	either side of street
	street	
7.2 m. to 8.7 m.	parallel parking on	no parallel parking on
	one side as decided	either side of street
	by Fairfax County	
	Office of Fire Marshal	
9 m. to 10.5 m.	parallel parking	parallel parking on one
	allowed on both sides	side as decided by Office
		of Fire Marshal
10.8 m. or greater	parallel parking	parallel parking allowed
	allowed on both sides	on both sides of street
	of street	

III. SIGN SPECIFICATIONS

- A. Metal construction, 305 mm x 457 mm
- B. Red letters on reflective with background with 10 mm red trim strip around entire outer edge of sign.

- C. Lettering on sign to be: "NO PARKING OR STANDING FIRE LANE"
- Lettering size to be as follows: "NO PARKING" and "STANDING" 50 mm, "OR" - 25 mm, "FIRE LANE" -63 mm, arrows 25 mm X 150 mm solid shaft with a solid head 38 mm wide and 50 mm deep.
- Signs are to be mounted 2.1 m. from the ground to the bottom of the Ε. sign unless otherwise directed by the Office of Fire Marshal.
- Posts for signs when required shall be metal and securely mounted, unless written permission for alternatives is obtained prior to installation from the Office of Fire Marshal. Signs should be spaced as on approved plans. In long stretches the maximum distance between signs is 21 m.
- G. Other special signs as approved by the Office of the Fire Marshal.

IV. CURB DESIGNATION

All curbs or paved spaces designated as fire lanes shall be indicated yellow paint approved by the Office of Fire Marshal. In areas without curbing, a 150 mm wide yellow stripe shall be applied to the edge of the pavement. Paint shall be highway traffic grade.

SIGN TYPE "A" SIGN TYPE "C" SIGN TYPE "D"

an arrow at bottom One sign mounted parallel to the line edge at end of painted edge at end of area.

Standard wording with Standard wording with Standard wording with an arrow at bottom no arrow. Two signs, pointing to the right. pointing to the left. back to back, mounted One sign mounted parallel to the line of curbing or of curbing or pavement of curbing or pavement pavement edge. painted area.

perpendicular to line

Fire lane markings, types of signs, locations, etc. shall be subject to the approval of the Office of the Fire Marshal.

V. INSPECTION NOTICE

- A. The following notice must appear on the site plans:
 - 1. Fire Marshal field inspection necessary for final approval of fire lanes. Fire lanes must have final approval prior to request for occupancy permit.
 - Owner shall notify the Fire Prevention Division, Fire Lanes Section, 4100 chain Bridge Road 4th Floor, Fairfax, Virginia 22030 (703-246-4821) when fire lanes have been installed.

VI. OTHER NOTICES TO BE SHOWN AS NEEDED

- A. Notes for fire department access lanes:
 - 1. To be an all weather surface designed to support fire department vehicles.
 - 2. To be identified as a fire lane at entrance.
 - 3. To be maintained clear and accessible all year.
 - 4. To have mountable curb at entrance.
 - 5. Provide manufacturer's specifications and installation instructions for items used in access lanes to Fire Marshal's office prior to installation.
 - 6. Installation of access must be witnessed by Fire Marshal's Office. Please call for an appointment.
 - 7. Provide approximately 1.2 m. high bollards with steel chain locked in between at curbside entrances to access lanes.
 - 8. Access lanes must be clearly delineated for entire length and at ends by shrubs, lights, etc.

One copy of the approved site plans will be retained by the Fire Prevention Division for future reference.